

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Shri Amit Sani, Supervisor
 (Name of Officers with designation) from Public Health Deptt. B.S.P.
 (Name of Department/ Office) inspected the Sree Narayana Guru Vidya Bhavan (Name & Address
 of the school) on 29.3.25 (Date of inspection) and found that the Sree Narayana
 Guru Vidya Bhavan (Name of school) has safe drinking water facilities for the students and members
 of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the
 campus as per norms prescribed by the Central/ State/ U.T. Govt. The above is valid for a period of

Signature with Seal: B.S.P.

Name

: Rajendra Kumar Singh

Designation

: Mgr (PHE-E)Name & Address of the Office / Department: T.S.D.

To

Sree Narayana Guru Vidya Bhavan
 St- 29, sector- 4, Bhilai

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,
 translated notarized version in English be uploaded along with the original vernacular certificate as a
 single pdf.

Bharati
 SREE NARAYANA GURU VIDYA BHAVAN
 SECTOR 4, BHILAI (C.G.)
 CBSE AFF. 3330390

Manager
 MANAGER
 SNGVB
 130



**WATER MANAGEMENT DEPARTMENT
BHILAI STEEL PLANT
LABORATORY, WTP, WMD**

IS 10500 : 2012

Sub: Drinking Water Analysis

Name of the party: SREE NARAYANA GURU VIDYA BHAVAN

Full Postal Address:

SING VIDYA BHAVAN, Street 29, Sector-4, Bhilai (C.G.) Date-01.03.2025

Location of sampling:

Type of water : BSP Supply/ Municipal Supply / Bore Well/

Sl.No	Substance or Characteristic	UNIT	Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate source	RESULTS
1. Physical Analysis					
a	Turbidity	NTU, max	1	5	0.88
b	pH Value		6.5 to 8.5	No Relaxation	7.7
2. Chemical Analysis					
a	Total Alkalinity	mg/lit	200 Max	600 Max	192
b	Total Hardness (as CaCO ₃)	mg/lit	200Max	600 Max	256
c	Ca Hardness (as CaCO ₃)	mg/lit	188 Max	500 Max	220
d	Mg Hardness (as CaCO ₃)	mg/lit	< Ca Hardness	< Ca Hardness	36
e	Chloride	mg/lit	250 Max	1000 Max	49
f	Iron as Fe	mg/lit	0.3 Max	No relaxation	BDL
3. Bacteriological Analysis					
a	Residual Chlorine	mg/lit	0.2 MIN	No relaxation	
b	MPN of Coliform Bacteria present in 100 ml of the original sample		NIL	No relaxation	Nil
4. Solids Analysis					
a	Total Solids	mg/lit			427
b	Dissolved Solids	mg/lit	500	2000	426
c	Suspended Solids	mg/lit			1
5. Special Analysis					
a	Sulphate as SO ₄	mg/lit	200 MAX	400 MAX	
b	Ammonia (as total Ammonia-N)	mg/lit, max	0.5	No relaxation	Nil BDL
6. Other Parameters					
	Colour	Hazen, max	5	15	

NOTE : This report is based on the water samples brought by the party at WTP, Maroda Lab.

AGM, WTP

Assistant General Manager
Water Management Deptt.
Bhilai Steel Plant

Asst. Chemist
Lab. WTP, WMD

MANAGER
SINGVB

Bhupati
SREE NARAYANA GURU VIDYA BHAVAN
SECTOR 4, BHILAI (C.G.)
CBSE AFF. 3330390